Intertek Intertek Intertek Intertek Intertek

Certificate of Constancy of Performance 0359-CPR-00287



In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation), this certificate applies to the construction product(s).

Product(s): Penton UK Limited's CELL10BT Range of Loudspeakers

(refer to attached appendix for details and conditions)

Produced by or for: Penton UK Limited

Unit 2, Teville Industrials, Dominion Way, West Sussex, BN14 8NW

Produced in the Penton Communications Incorporated

manufacturing plant(s): No. 28-2, Ya-Tan Road, Ta-Ya, Taichung, Taiwan

Intended use: Fire Safety

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the

standard(s):

EN54-24:2008

Fire detection and fire alarm systems. Components of Voice Alarm

Systems - Loudspeakers

Under system 1 are applied and that the product(s) fulfils all the prescribed

requirements set out above.

This certificate was first issued on 1st May 2014 and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing

conditions in the plant are not modified significantly.

Notified Body 0359

Intertek Testing & Certification Limited

Cleeve Road, Leatherhead Surrey, KT22 7SB

Tel: + 44 (0)1372 370900 Fax: +44 (0)1372 370977 E-mail: cpd.uk@intertek.com Daniel Griffin

Certification Manager

5

Date 1/5/2014

Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

Certificate of Constancy of Performance 0359-CPR-00287



Appendix to Certificate of Constancy of Performance 0359-CPR-00287

The details and condition of use for Penton UK Limited's CELL10BT Range of Loudspeakers, placed on the market by:

Penton UK Limited

Unit 2, Teville Industrials, Dominion Way, West Sussex, BN14 8NW

To be used in accordance with the supplier's installation instructions and in conjunction with the following bases, ancillaries, sounder tones and sensitivity settings (where applicable):

Products compliant with EN54-24:2008

Variant Description

CELL10BT/EN 20W, Type B, bi-directional sound projector

CELL10BT/ENC 20W, Type B, bi-directional sound projector with capacitor

Conditions of use:

Suitable for outdoor (Type B) applications

General Notes:

- Evaluated under Intertek project number 10049484.
- The Model CELL10BT/EN and Model CELL10BT/ENC shall have the following equaliser settings applied:
 - +6.0dB at 630 Hz
 - +3.5dB at 800 Hz
 - -3.5dB at 1250 Hz
 - -3.5dB at 1600 Hz
 - -2.5dB at 4000 Hz
- 3. No CE or other type approval is made or inferred outside of the attestation of conformity and the product performance as stipulated on this certificate.

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00287 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

Certificate of Constancy of Performance 0359-CPR-00287



Appendix to Certificate of Constancy of Performance 0359-CPR-00287 (continued)

Table of performance for EN54-24:2008 Harmonised technical specification			
Essential characteristics	Performance	Clauses	Notes
Performance under fire condition.	Pass	4.2, 5.2, 5.3, 5.4, 5.5	а
Operational reliability	Pass	4.3, 4.4, 4.5, 5.6, 5.18	b
Durability of operational reliability: temperature resistance	Pass	5.7, 5.8, 5.9	b
Durability of operational reliability: humidity resistance	Pass	5.10, 5.11, 5.12	b
Durability of operational reliability: corrosion resistance	Pass	5.13	
Durability of operational reliability: impact and vibration resistance	Pass	5.14, 5.15, 5.16, 5.17	

Notes:

Intertek Testing & Certification Limited, Cleeve Road, Leatherhead, Surrey, KT22 7SB Tel: + 44 (0)1372 370900, Fax: +44 (0)1372 370977, E-mail: cpd.uk@intertek.com

0359-CPR-00287 Issue 1

www.intertek.com

Registered No 3272281 Academy Place, 1-9 Brook Street, Brentwood, Essex, CM14 5NQ, United Kingdom

a. The products covered by this standard are assumed to enter the alarm condition, in an event of fire, before the fire becomes so large as to affect their functioning. There is therefore no requirement to function when exposed to direct attack from fire.

b. For Clauses 5.7, 5.9, 5.10 and 5.18, Type B conditioning was applied.